



# **Multiple Pipeline Tools Used to Rehab/Replace 7-mile Pressure AC Main**

**CA NV AWWA, Pipeline Rehabilitation Committee**

**October 1, 2013**

**By Tim Williams and Tracie Mueller,  
Kennedy/Jenks Consultants**



# Multiple Tools Outline

- Project Overview
- AC Pipe Investigations
- Five Phased Rehabilitation and Replacement Approach
- Rehab and Replacement Tools and Lessons Learned
- Project **Cost Summary**

# Project Overview

- 7-mile AC Pipeline – Industrial Wastewater Force Main constructed in 1976
- Conveys tomato (1976 to 1999) and fruit canning (2000 to present) waste from Factory to Industrial Waste Treatment and Land Application site




# Pipeline Break History

- Over 10 breaks, varying from 1 to 3 per year for over a decade



# Pipe Profile





# AC Pipe Investigations

- Client had inadequate funds to replace pipeline, and factory shutdown cost up to \$1M per day
- Risk Analysis - estimate pipe condition, ability to meet service conditions, and remaining useful life
  - Evaluated breaks from 1984 to 2008
  - Conducted “C” factor test
  - Investigated pipe construction
- RWQCB closely monitoring industrial sewer spills from pipeline breaks

# Methods to Investigate Pipe Breaks

- Photograph and physically review specimens
- Measured by caliper micrometer and depth of softness of the surface by Starrett® pitting gauge



# Pipe Breaks

- Circumferential breaks – flexural displacement load
- Longitudinal breaks – internal pressure and bursting failure





# Pipe Break Investigation

Year	Class 150, 1.25" wall thickness	Class 100, 0.85" wall thickness	No. of Breaks	Wall Thickness measured, in.	Estimated Remaining Useful Life
1988	X		1	1.125"	30 years
1995	X	X	2	1.055" / 0.73"	5 to 10 years
1998	X		1	1.03" / 0.63"	3 to 7 years
2002		X	3	0.535" to 0.55"	2 to 5 years
2004		X	2	0.60" to 0.631"	2 to 5 years

**Average pipe loss 10 to 15 mils/yr interior  
and 1 to 2 mils/yr exterior**



# 1998 - Conducted “C” Factor Test

- No services along pipeline
- Used external ultrasonic flow meter
- Added pressure gauges along alignment at CAVs
- Operated pumps and measured pressure
- Estimated Hazen Williams “C” factors by pipe segments
- Results: HW “C” 85 to 105 for Class 150 AC
- Impacts: Increased Pressures for Class 150 AC and conveyance capacity reduced



# Cause of Breaks

- Construction methods – poor backfill and bedding causing settlement and circumferential cracks
- Increased surge effects with 2<sup>nd</sup> pump activation causing longitudinal cracks
- Deterioration of pipe wall thickness – leaching of calcium from pipe, soft fibrous profile
- Investigation and estimated useful life basis:
  - Allow up to half the wall thickness in Class 150 before critical to replace pipe
  - Reduces safety factor from 4:1 to 2:1 bursting resistance



# Recommended Improvements


## Immediate:

- Add soft start to 2<sup>nd</sup> pump to reduce surge
- Add flow monitoring system – increase pipe alignment inspection
- Develop emergency bypass system across UPRR and State Highway Crossing

## Near-Term:

- Replace pipeline in phases correcting highest risk to lowest risk segments

# Phased AC Pipeline Replacement





# Preliminary Design Report

- Evaluated Pipe Materials & Construction Methods
  - Open cut remove & replace with PVC C900 or HDPE pipe
  - Open cut parallel PVC or HDPE pipe
  - Pipe bursting with HDPE pipe
  - Re-lining using CIPP or Fold-n-Form
  - Re-using steel casings and remove & replace existing AC carrier pipe

# Evaluation of Alternatives

Evaluating Criteria	Phases 1 & 2			Phases 3 & 4		
	Alt 1-1: Open Cut	Alt 1-2: Re-lining	Alt 1-3: Combo	Alt 1-1: Open Cut	Alt 1-2: Re-lining	Alt 1-3: Combo
Constructability	6	10	8	4	10	8
Schedule to Complete	6	10	8	6	10	8
Easement requirements	6	9	8	4	10	6
Utility impacts	7	9	8	6	10	10
Active railroad and road crossing impacts	7	9	9	6	10	10
Environmental impacts	6	9	8	4	10	8
Permitting	6	10	7	6	10	8
Operational impacts - storm water collection and disposal	6	6	6	6	6	6
Ease of Operations (including pigging)	10	4	4	10	4	4
Total Project Cost	40	24	32	28	32	40
<b>Total</b>	<b>100</b>	<b>100</b>	<b>98</b>	<b>80</b>	<b>112</b>	<b>108</b>



## **Actual Pipe Materials and Construction Methods Used**

- Client wanted a new pipe & was willing to pay for it
  - **Phase A: Open cut – parallel PVC pipeline**
  - Phase 1: Open cut - reused casings and replaced AC pipe with HDPE in casings and PVC outside of casings
  - Phase 2: Open cut – remove and replace with PVC
  - Phase 3: Open cut – remove and replace combined with parallel pipeline with PVC
  - **Phase 4: Open cut – parallel PVC pipeline with pipe bursting using HDPE at crossings**
- \*Phases A & 4 – direct negotiation w/ preferred contractor**



# Phase 1 – Lessons Learned

- Original plan pull pipe from casings
  - Check both ends of each casing
- CO - Drilled out AC pipe in (E) casing for UPRR
  - AC haz mat trained personnel on-site
  - Special monitoring for AC friables
  - Enclosure and capture air
  - Capture and dispose of drilling muds



# Phase 1 – Lessons Learned

- Use an experienced trenchless contractor
- CCTV & pressure test pipe after installation
- Avoid grouting within casings if possible




# Phase 4 – Investigation

- Pipe Bursting used to cross creeks – HDPE, DR 13.5, 11.80” pipe ID - no impact to pigging operation
  - Only required 1602 Streambed Alt Permit
- Excavated soil test pits for pipe bursting at creek crossings
- Limited pipe bursting to <260’ to avoid USEPA, Asbestos National Emission Standards for Hazardous Air Pollutants (NESHAP)



# Phase 4 – Implemented Lessons Learned

- Investigated pipe caps – confirmed only on top half of pipe
  - Cut out sample and tested
  - Concrete compressive test – 5,880 psi
- County roads – open cut, installed casings & carrier pipe



# Open Cut – Remove & Replace

## Lessons Learned

### AC Pipe Removal and Replacement:

- Remove AC intact
- Bag AC pipe
- Dispose at landfill able to take AC pipe intact

### Abandon Casing for Parallel Construction:

- Fill pipe to avoid pipe/casing failure and road settlement



# Project Cost for 12" Ø AC Pipeline Replacement

Phase (Year)	Description	Bid	Change Orders	Final	Engineers Estimate	Savings
A (2003)	2,500' remove & replace	\$156K	\$0K	\$156K	\$211K	\$55K
1 (2008)	789' remove & replace & 243' pull pipe from casing (CO to drill out AC)	\$136K	\$164K	\$300K	\$253K	-\$46K
2 (2010)	2,429' remove & replace + additional 1,850' through CO	\$178K	\$170K	\$348K	\$427K	\$79K
3 (2011)	1,650' remove & replace & 2,887' parallel pipe	\$300K	\$2K	\$302K	\$313K	\$9K
4 (2013)	17,000' parallel pipe, 380' remove & replace, & 400' burst	\$1,121K	\$0K	\$1,121K	\$1,137K	\$16K
Total	30,128'	\$1,891K	\$336K	<b>\$2,227K</b>	\$2,350K	\$103K



# Questions?

## Contact:

**Tim Williams – (916) 858-2722 or  
[timwilliams@kennedyjenks.com](mailto:timwilliams@kennedyjenks.com)**

**Tracie Mueller – (916) 858-2721 or  
[traciemueller@kennedyjenks.com](mailto:traciemueller@kennedyjenks.com)**